



Department of Energy

3318



Ohio Field Office
Fernald Area Office
P. O. Box 538705
Cincinnati, Ohio 45253-8705
(513) 648-3155

001 10 2000

Mr. Gene Jablonowski, Remedial Project Manager
U.S. Environmental Protection Agency
Region V, SRF-5J
77 West Jackson Boulevard
Chicago, Illinois 60604-3590

DOE-0014-01

Mr. Tom Schneider, Project Manager
Ohio Environmental Protection Agency
401 East 5th Street
Dayton, Ohio 45402-2911

Dear Mr. Jablonowski and Mr. Schneider:

**SILOS 1 AND 2 ACCELERATED WASTE RETRIEVAL PROJECT DESIGN CHANGE NOTICE
AWR-DCN-C-0004**

Reference: Letter, B. Lohner to N. Akgündüz, "Revision to the Location of the Electrical Building," dated August 2, 2000

The Ohio Environmental Protection Agency (OEPA) approved Silos 1 and 2 Accelerated Waste Retrieval (AWR) Project Design Change Notice (DCN) AWR-DCN-C-0004 (see Referenced letter). This DCN proposed to relocate the location of the Electrical Building seven feet to the north due to the discovery of an existing buried electrical duct bank at the south side of the originally proposed location for the building. As a condition of approving the DCN, the OEPA requested a copy of the drawing demonstrating that the location of the duct bank had been formally documented in site records, and confirmation of the Department of Energy (DOE) intent to remove the duct bank as part of future Decontamination and Decommissioning (D&D) activities.

Enclosed is a copy of the Fernald Environmental Management Project (FEMP) Drawing No. 22A-5500-P-00805, "Grid 31B Underground Utilities," Revision 21, dated August 16, 2000. This latest revision of the drawing incorporates the location of the duct bank, as well as other recently identified underground utilities.

3318

Mr. Gene Jablonowski
Mr. Tom Schneider


-2-

OCT 14 2000

As stated in the referenced DCN, DOE intends to remove this newly discovered duct bank, as well as foundations. Other below-grade piping, duct banks, etc., in the Silos area will take place as part of future D&D.

If you have any questions, please contact Nina Akgündüz at (513) 648-3110.

Sincerely,



Johnny W. Reising
Fernald Remedial Action
Project Manager

FEMP:Akgündüz

Enclosure

cc w/enclosure:

T. Schneider, OEPA-Dayton (three copies of enclosures)
M. Schupe, HSI GeoTrans
F. Hodge, Tetra Tech
AR Coordinator, Fluor Fernald, Inc./78

cc w/o enclosure:

S. Fauver, EM-31/CLOV
N. Akgündüz, OH/FEMP
J. Lorence, OH/FEMP
A. Murphy, OH/FEMP
A. Tanner, OH/FEMP
J. Saric, USEPA-V, SRF-5J
R. Vandegrift, ODH
D. Carr, Fluor Fernald, Inc./2
R. Fellman, Fluor Fernald, Inc./2
T. Hagen, Fluor Fernald, Inc./65-2
J. Harmon, Fluor Fernald, Inc./90
S. Hinnefeld, Fluor Fernald, Inc./31
D. Nixon, Fluor Fernald, Inc./52-4
D. Paine, Fluor Fernald, Inc./52-4
T. Walsh, Fluor Fernald, Inc./65-2
ECDC, Fluor Fernald, Inc./52-7

2



3318

State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249

Bob Taft, Governor
Maureen O'Connor, Lt. Governor
Christopher Jones, Director

To: Nina Akgunduz, DOE, Fernald
From: Bill Lohner, Ohio EPA
Re: Revision to the location of the Electrical Building
Date: August 2, 2000

The following was transmitted via e-mail on July 26, 2000.

DCN: AWR-DCN-C-0004

This DCN changes the location of the electrical building 7 feet to the north. The move is necessary due to the discovery of an existing buried electrical duct bank at the south side of the electrical building.

The Ohio EPA approves this change with the following conditions:

1. The location of the duct bank is formally added to the appropriate site drawings to ensure that its existence and specific location is documented when the foundations and other below-grade piping, duct banks, etc. are removed.
2. A copy of this drawing, denoting the location of the duct banks, be provided to Ohio EPA upon its completion. A cover letter should also be provided with the drawing stating DOE's intent to remove the duct bank during future D&D of the area.